



MEMO

Date: 7/13/07

To: ALL CITY DEPARTMENTS

From: Terry Palmer, Water Treatment Plant Manager

RE: Main Break – Summit Rd between Pigeon Creek and McCoy Rd

A 24" water main broke at approx. 8:00 pm on Thursday, July 12, 2007, on Summit Road between Pigeon Creek and McCoy Road. The break area was isolated and the main repaired. Water service in the affected area was returned by 4:00 am on Friday, July 13, 2007.

A precautionary boil advisory has been issued for the area around the break. The consumers affected by the precautionary boil advisory were notified by red colored cards hung on a door at the location of water service and on Barberton's website, <http://www.cityofbarberton.com>. The area under a precautionary boil advisory is:

- Summit Road from Pigeon Creek to the south side of Interstate 76.
- McCoy Road
- McGowan Road
- Berry Rd between McCoy Rd and McGowan Rd

The tap water used for drinking should be brought to a rolling boil for one minute.

The precautionary boil advisory could be in effect for 24 – 48 hours after the main is repaired. The precautionary boil advisory will not be lifted until we are sure the water is safe to drink. Even after the advisory is lifted the water could be discolored in some areas.

The precautionary boil advisory will be lifted through green colored cards hung on a door at each location affected and on Barberton's website, <http://www.cityofbarberton.com>.

Thanks,

Terry Palmer

Water Treatment Plant Manager
3365 Summit Rd.
Norton, Ohio
Phone 330-848-6744